

PORT OF GUAM
ATURIDAT I PUETTON GUAHAN
Jose D. Leon Guerrero Commercial Port
1026 Cabras Highway, Suite 201, Pitl, Guam 96915
Telephone: 671-477-5931/35 Facsimile: 671-477-2689/4445
Website: www.portguam.com



AMENDMENT NO. 2

DATE: March 22, 2023

INVITATION FOR BID No. PAG-012-23 PAG GENERATOR MAINTENANCE AND SUSTAINMENT

NOTICE TO OFFERORS: The IFB documents of the above referenced project are hereby amended to include the following as part of IFB documents:

- 1. Amend to change pages 34-36 of the IFB with Revised 3/21/2023 Page 34 of 36 through Revised 3/21/2023 Page 36 of 36.
- 2. Amend to change bid submittal date to read from March 27, 2023 at 2:00PM to now read March 29, 2023 at 2:00PM

*** END OF AMENDMENT NO. 2, ALL OTHERS REMAIN THE SAME ***

	General Manager
NAME OF PROPOSER:	(materials to the control of the con
AUTHORIZED SIGNATURE:	
PRINT NAME:	
DATE/ TIME:	

GENERAL DESCRIPTION

ALL OR NONE

The Port Authority of Guam is Procuring a Technical Support Contract for Diagnosis, Repair and Testing of its thirteen (13) Caterpillar Power Generator Sets: (7) each 455KW, (1) each 725KW, and (5) each 910KW Caterpillar C32 Generator Sets to include the Automatic Transfer Switches and Day Tanks. One (1) contract year with two (2) additional option years.

BR	REAKDOV	WN OF SERVICES			
1.	Technic	cal Repair Services			\$
		e Hourly Cost			
	Will be	awarded as a lump sun		to the successf	ul bidder
	based o	n the hourly rates below	V.		
					Bidding On/Remarks
	Auto troul	omatic Transfer Switche	asis for Troubleshoes, Day Tanks, and repair, calibration,	ot/Repair of eig piping. These s	and piping ht (8) Generator Sets to include ervices are to include inspection, and testing. This is to include
	Day repa	Tanks, and piping. The	asis for Troubleshorse services are to in	ot/Repair of fiviclude inspection	ing e (5) Generator Sets to include n, troubleshooting, diagnosis, e Parts and Material as required
	1.3	A comprehensive reposubmitted to the Port performed under technology	for every trouble sl	looting and/ or i	
	1.4	For trouble calls the se	uccessful bidder m	ust respond witl	nin 1 hour.
	1.5	Services performed sl	hall not exceed a m	aximum of 300	hours per year.
į	Hourly R	ates and Fixed Fees Sc	hedules. This app	lies to line item	1.1 and 1.2.
	a.) Fiel	d Labor Hours	\$	/hr	
		ertime Field Labor	\$	/hr	
		iday Rate	\$	/hr	
	d.) Tra		\$	/hr	
	e.) Ove	ertime Travel	\$	/hr	
	AVERAG	E TOTAL OF HOUR	LV RATES (a+b	rc+d+e)/5= \$	(Place this
		n line 1 for evaluation		_	(4 IMOU THIS
		average will be used f nd be drawn down o			warded, hourly rates will be
2.	Load B	Bank Test	1	LT	\$
	Thirtee	en (13) Generator Sets			
					nen the unit cannot be loaded to a hours, or after any significant

least 30% of the generator's rated capacity for at least four (4) hours, or after any significant repair work to ensure genset is ready before returning to standby/ready mode with its regular electrical load. Loading the unit will burn off harmful deposits in the combustion chamber, injector nozzles, and exhaust system.

	incrementally and at least 75% rated load. Provide record dat and note engine operating condition.	a	
3.	Bi-annual Inspection Report	\$	
	3.1 Report must include assessment and corrective action	<u></u>	
	3.2 Must include quotation for corrective action not limited to required parts.		

2.1 Test generator set with load banks for up to four (4) hours

NOTES:

A. All Items

- 1. All Services to be performed, as specified on all Items, are for a period of one (1) year with an option for two (2) additional years.
- All Services are to be perform by Certified Technicians who have completed training on, and
 have access to, diagnostic software that can interface, communicate, and program these specific
 Caterpillar generator sets.
- 3. All services rendered will be based on Bidder's fixed fee schedule for travel, labor (regular & overtime), tools, material, and other related services.
- 4. Bidder will include in every invoice: detail of work performed, date and time period of work performed, Technician name(s) performing work, and Port's point of contact during specific visits.
- All Services are for the following Generator-Sets: thirteen (13) Caterpillar Generator Sets, eight
 Automatic Transfer Switchgear, twelve (12) Day tanks.

	Automatic Transfer Switch	Above-ground Storage Tank
Generator	(ATS)	(Day tanks)
Load Center No.1	ASCO Series 300	
455KW, C15 S/N T4A00897	Cat. No. H300B31200N1C	500 gal. AST
	S/N 173878	
L	277/480V 1200A	1
Load Center No. 2	Caterpillar CTS	
455KW, C15, S/N T4A00858	S/N TSG04251	500 gal. AST
	277/480V 3000A	
Load Center No. 3	Caterpillar CTS	
455KW, C18, S/N G6B26833	S/N TSG05337	500 gal. AST
	277/480V 2000A	
Load Center No. 4	Caterpillar CTS	
455KW, C15, S/N T4A00860	S/N TSG01971	500 gal. AST
	277/480V 3000A	
Load Center No. 4	Caterpillar CTS	
725KW, C27, S/N T4Z00481	S/N TSG01972	1000 gal. AST
	120/240V 3000A	
Load Center No. 5	Cummins Power Generation	
455KW, C15, S/N T4A00813	Switchgear 277/480V 3200A:	275 gal. AST
	Model: SWG0303G-0021A	
	S/N J140766347 (Section 1 of 5),	
	Digital Master Control:	
	Model: PCU0303G-0016A	
	S/N J140760050 and	

	Model: MOD9999G-0050A S/N B150794071	
Load Center No. 5 455KW, C15, S/N T4A00814	Same as above (Load Center No. 5)	275 gal. AST
Load Center No. 5 455KW, C15, S/N T4A00816	Same as above (Load Center No. 5)	275 gal. AST
N/A	N/A	Load Center No. 5 Feeder Tank 3000 gal, AST
Gantry Crane No. 4 910KW, C32, S/N SXC05456	N/A	1500 gal, AST
Gantry Crane No. 5 910KW, C32, S/N PEF00157	N/A	1500 gal. AST
Gantry Crane No. 6 910KW, C32, S/N PEF00158	N/A	1500 gal. AST
Gantry Crane Stand-by 910KW, C32, S/N SXC03553	N/A	N/A
Gantry Crane Stand-by 910KW, C32, S/N SYC03485	N/A	N/A

B. Item No. 1.1

- Generator Sets are located ground level at PAG Load Centers in the Port secured compound at Cabras Island, Piti, GU. Awarded Bidder must comply with requirements for the entry of its personnel and vehicles into the Port security areas. As outlined on Policy Memorandum No. 97-01, there is auto liability, commercial general liability, and worker compensation insurance requirements; depending on the type of activity to be conducted by Vendor representative(s) entering the Port security area. Copy of the policy memorandum can be made available for review.
- Item No.1 also covers service maintenance of each genset's corresponding Automatic Transfer Switch gear in accordance with manufacturers' guidelines:
 - Clean transfer switch as needed.
 - Check condition of contacts.
 - Check for loose, broken or worn parts.
 - Test breaker trip for proper operation.
 - Test protective relay for proper operation.
 - Verify calibration and adjust if necessary.
 - Review components of switchgear.
 - Test switchgear operation sequence.

C. Item No. 1.2

1. Generator Sets are located at the PAG Gantry Cranes - location 50 feet above ground level, accessible only via fixed ladders/stairs system, or a boom man-lift. Fall protection required at all times during climb/descent.

These specifications were developed by: Brenda Attilig-Planner, Alex Aflague-Facilities Maintenance Superintendent and Shine San Agustin- Equipment Maintenance Superintendent (acting), and then reviewed by: Joe Javellana- Chief Planner, Glenn B. Nelson-Maintenance Manager (Acting), and finally approved by: Rory J. Respicio-General Manager of the PAG