

INVITATION FOR BID

ISSUING OFFICE:

PORT AUTHORITY OF GUAM
Government of Guam
1026 Cabras Highway, Ste. 201,
Piti, Guam 96915


RORY J. RESPICIO
General Manager

DATE ISSUED: May 13, 2024

INVITATION FOR BID No.: IFB/PAG-014-24

BID FOR: **OVERHAUL OF 910KW CATERPILLAR C-32 GENERATOR ENGINE**

SPECIFICATIONS: **SEE ATTACHED**

DESTINATION: **PORT AUTHORITY OF GUAM**

REQUIRED DELIVERY DATE: 90 Days Upon Receipt of Purchase Order. Delivery schedule time will be coordinated between the successful bidder and the requesting department. For a period of One (1) year with an option to renew for an additional of 2 one-year option upon availability of funds.

INSTRUCTION TO BIDDERS:


INDICATE WHETHER: INDIVIDUAL PARTNERSHIP CORPORATION

INCORPORATED IN: Hawaii

THIS BID SHALL BE SUBMITTED in duplicate with one (1) electronic copy and sealed to the issuing office above before or until **Tuesday, May 28, 2024, at 2:00 p.m., Chamorro Standard Time (Guam Time)** and shall be publicly opened. Any Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions, and Sealed Bid Solicitation for details.

The undersigned offers and agrees to furnish within the time specified, the articles and services at the price stated opposite the respective items listed on the schedule provided unless otherwise specified by the bidder. In consideration of the expense of the Government in the opening, tabulating, and evaluating this and other bids, and other considerations, the undersigned agrees that this bid remains firm and irrevocable within **90** calendar days from the date of opening to supply any or all the items which prices are quoted.

NAME AND ADDRESS OF BIDDER:
Hawthorne Pacific Corp.
196 East Harmon Industrial Park Road
Tamuning, Guam 96913

SIGNATURE AND TITLE OF PERSON AUTHORIZED TO SIGN THIS BID:
Jeffrey Boman
Digitally signed by Jeffrey Boman
DN: cn=Jeffrey Boman, o=Hawthorne Pacific Corp., ou=Hawthorne Pacific Corp., email=jboman@hpcorp.com, c=US
Date: 2024.05.13 09:52:14 -0700
Jeffrey Boman, Corporate Secretary


AWARD: CONTRACT NO.: IFB/PAG-014-24 **AMOUNT:** \$168,711.70 **DATE:** 07/12/2024

ITEM NO(S). AWARDED: Line Item 1

NAME AND ADDRESS OF CONTRACTOR:
Hawthorne Pacific Corp.
196 East Harmon Industrial Park Road Tamuning, Guam 96913

CONTRACTING OFFICER:

RORY J. RESPICIO
General Manager

SIGNATURE AND TITLE OF PERSON AUTHORIZED TO SIGN THIS CONTRACT:
Jimmy Cruz - Jimmy Cruz
Name: Account Manager **Date:** 9/16/24

<u>Item No.</u>	<u>Description</u>	<u>Qty</u>	<u>Unit</u>	<u>Unit Price</u>	<u>Extended Price</u>
1.	Complete Overhaul Service for One (1) Generator Set	1	SE	\$ 168,711.70	\$ 168,711.70

Model: Caterpillar C-32 910KW Prime Power

<u>Year</u>	<u>Serial Nos.</u>	<u>Hours of Usage</u>
2019	PEF00157	13160.3

Scope of Work:

1. Complete overall work is to be performed by a certified Caterpillar technician(s). The awarded bidder's technician must have training, certification, and access to the Caterpillar Electronic Software (ET).
2. All replacement parts must be new and genuine (OEM) by a generator set manufacturer Caterpillar. Only New and Remanufactured Caterpillar parts are acceptable.

New Replacement Parts to include;

Cylinder Head assembly's, Connecting Rods, Pistons, Cylinder Liners, Cylinder Packs, Camshafts, Fuel Pumps, Fuel Cooler, Fuel Injectors, Fuel Lines, Turbochargers, Oil Pumps, Oil Cooler, Transfer Pumps, Thrust Bearings, Main Bearings, Rod Bearings, Valve Rotators, Crankshaft Seals, All Hoses, Fuel, Oil and Air Filters, Gaskets, O-rings, Belts, Clamps, Fasteners, Fitting and Plugs. Engine Block, Crankshaft, Ports, and Journals Cleaned and inspected to be within the Manufacturers Acceptable Specifications.

3. Complete overhaul of the generator set to include the replacement of Generator End Bearing (Coupling, Element, and Washers). The generator set is to be cleaned and inspected for damage.
4. One (1) Year Warranty on Parts. Warranty shall begin upon installation of the generator set to the Gantry Crane.
5. Overhaul service of one (1) generator with an option to service an additional one (1) generator. This contract shall not exceed the maximum total of two (2) generator set overhaul services.
 1. S/N PEF00157
 2. S/N ASXC03553
6. Must pass post-overhaul full load test at 100% for a duration of no less than 60 minutes. The awarded bidder shall be responsible for conducting this fuel and load bank test.
7. Overhaul services to be done offsite.
8. Complete overhaul for the generator set is to be completed in ninety (90) days.

THESE SPECIFICATIONS HAVE BEEN DEVELOPED BY THE PORT AUTHORITY OF GUAM EQUIPMENT MAINTENANCE DIVISION; EVELYN PANGELINAN, MAINTENANCE PLANNER, AND GUS AROMIN, ACTING CRANE MAINTENANCE SUPERVISOR, REVIEWED BY SHINE SAN AGUSTIN, ACTING EQUIPMENT MAINTENANCE SUPERINTENDENT, JOAQUIN PANGELINAN, MANAGER EQUIPMENT SUPPORT SERVICES, GLENN NELSON, ACTING MAINTENANCE MANAGER AND APPROVED BY RORY RESPICIO, GENERAL MANAGER.